

NSF/ANSI 55 – 2002
Addendum 2.0 – 2002

Ultraviolet microbiological water treatment systems

NSF International Standard/
American National Standard

NSF/ANSI 55 – 2002
Addendum 2.0 – 2002



NSF International, an independent, not-for-profit, non-governmental organization, is dedicated to being the leading global supplier of public health and safety-based risk management services serving the interests of all stakeholders.

This Addendum is subject to revision.
Contact NSF to confirm this revision is current.

Users of this Addendum may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Drinking Water Treatment Units
c/o NSF International
789 North Dixboro Road, P.O. Box 130140
Ann Arbor, Michigan 48113-0140 USA
Phone: (734) 769-8010 Telex: 753215 NSF INTL
FAX: (734) 769-0109 E-mail: info@nsf.org
Web: <http://www.nsf.org>

NSF International Standard/
American National Standard
for Drinking Water Treatment Units –
**Ultraviolet microbiological
water treatment systems**

Standard Developer
NSF International

Adopted October 5, 2002
NSF International

Designated as an ANSI Standard
October 5, 2002
American National Standards Institute

Prepared by
The NSF Joint Committee on Drinking Water Treatment Units

Recommended for Adoption by
The NSF Council of Public Health Consultants

Adopted by
The NSF Board of Directors
May 1991

Revised January 2000
Revised January 2002
Addendum, June 2002
Addendum, October 2002

Published by

NSF International
PO Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this Standard, please reference the designation “NSF/ANSI 55 – 2002, Addendum 2.0 – 2002.”

Copyright 2002 NSF International
Previous edition © 2000, 1991

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

Disclaimers¹

NSF, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirements.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include **all** requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

¹ The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally blank.

Contents

3 Definitions 1

6 Bacteriological, chemical, mechanical, and structural performance 1

6.6 Structural integrity..... 1

Table 5 – Structural integrity testing requirements 2

This page is intentionally blank.

NSF/ANSI Standard
for Drinking Water Treatment Units —

Ultraviolet microbiological water treatment systems

3 Definitions

3.10 disposable pressure vessel: A pressure vessel that is to be replaced at the end of each rated service cycle and has an estimated service life of one year or less.

3.23 pressure vessel: A component of the system, intended to hold water under pressure higher than atmospheric pressure.

6 Bacteriological, chemical, mechanical, and structural performance

6.2 Structural integrity

6.2.1 ~~General~~

The purpose for testing structural integrity performance is to evaluate the materials, design, and fabrication quality of the complete water treatment system.

~~6.2.2~~ 6.2.1 Acceptance

Each test of structural integrity (cyclic pressure, hydrostatic pressure, and burst pressure) shall be performed on a separate system. If the complete water treatment system is tested, a separate test of the system pressure vessel is not required.

Complete systems, pressure vessels, and components shall be tested for structural integrity in accordance with 6.2.3 at the pressures specified in table 5. When more than one pressure is specified in table 5, testing shall be done at the higher pressure.

Complete systems, pressure vessels, and components shall be water tight when tested for structural integrity under 6.2.3.

Revisions to NSF/ANSI 55 – 2002 are shown in this addendum as **crossouts** for deletions and **highlights** for additions.

NSF/ANSI 55 – 2002
Addendum 2.0 – 2002

© 2002 NSF

Table 5 – Structural integrity testing requirements

Complete systems	Hydrostatic pressure test¹	Burst pressure test¹	Cyclic pressure test¹
complete systems with pressure vessels having a diameter < 203 mm (8 in)	3 x maximum working pressure or 2,070 kPa (300 psig)	none	100,000 cycles at 0 to 1,040 kPa (0 to 150 psig) or maximum working pressure
complete systems with pressure vessels having a diameter of \$203 mm (8 in)	1.5 x maximum maximum working pressure or 1,040 kPa (150 psig)	none	100,000 cycles at 0 to 1,040 kPa (0 to 150 psig) or maximum working pressure
complete systems designed for open discharge ²	1.5 x maximum working pressure or 1,040 kPa (150 psig)	none	10,000 cycles at 0 to 345 kPa (0 to 50 psig)
complete portable systems pressurized by user ³	1.5 x maximum working pressure	none	none
Components	Hydrostatic pressure test	Burst pressure test	Cyclic pressure test
Permanent metallic pressure vessels having a diameter < 203 mm (8 in) ⁴	3 x maximum working pressure or 2,070 kPa (300 psig)	none	100,000 cycles at 0 to 1,040 kPa (0 to 150 psig) or maximum working pressure
Permanent metallic pressure vessels having a diameter of \$ 203 mm (8 in) ⁴	1.5 x maximum working pressure or 1,040 kPa (150 psig)	none	100,000 cycles at 0 to 1,040 kPa (0 to 150 psig) or maximum working pressure
Permanent nonmetallic pressure vessels having a diameter < 203 mm (8 in)	3 x maximum working pressure or 2,070 kPa (300 psig)	4 x maximum working pressure or 2,760 kPa (400 psig)	100,000 cycles at 0 to 1,040 kPa(0 to 150 psig) or maximum working pressure
Permanent nonmetallic pressure vessels having a diameter of \$ 203 mm (8 in)	1.5 x maximum working pressure or 1,040 kPa (150 psig)	4 x maximum working pressure or 2,760 kPa (400 psig)	100,000 cycles at 0 to 1,040 kPa (0 to 150 psig) or maximum working pressure
disposable metallic pressure vessels and components	3 x maximum working pressure or 2,070 kPa (300 psig)	none	10,000 cycles at 0 to 1,040 kPa (0 to 150 psig) or maximum working pressure
disposable nonmetallic pressure vessels and components	3 x maximum working pressure or 2,070 kPa(300 psig)	4 x maximum working pressure or 2,760 kPa (400 psig)	10,000 cycles at 0 to 1,040 kPa (0 to 150 psig) or maximum working pressure
valves and controls ⁵	none	none	100,000 cycles at 0 to 1,040 kPa (0 to 150 psig) or maximum working pressure

Revisions to NSF/ANSI 55 – 2002 are shown in this addendum as ~~crossouts~~ for deletions and **highlights** for additions.

© 2002 NSF

NSF/ANSI 55 – 2002
Addendum 2.0 – 2002

Table 5 – Structural integrity testing requirements

Complete systems	Hydrostatic pressure test ¹	Burst pressure test ¹	Cyclic pressure test ¹
<p>¹ When a choice is given in the table, testing shall be done at the greater pressure.</p> <p>² Components downstream of the system on/off valve that are not subject to pressure under the off mode, and that either contain no media subject to plugging or are not designed to contain media shall be exempt from the hydrostatic pressure test, but shall be watertight in normal use. Components that are downstream of the system on/off valve but upstream of media subject to clogging shall meet the requirements of this section.</p> <p>³ Portable systems designed to utilize only atmospheric pressure or gravity flow shall be exempt from the hydrostatic pressure test, but shall be watertight in normal use.</p> <p>⁴ Permanent Metallic pressure vessels require measurement of permanent circumference and head deflection. The pressure vessel circumference shall not exhibit a permanent increase of more than 0.2% when measured at the midsection and at 30 cm (12 in) intervals. The top and bottom head deflection of the pressure vessel shall not exhibit a permanent deflection exceeding 0.5% of the vessel diameter.</p> <p>⁵ Subject to line pressure and tested as separate components.</p>			

Revisions to NSF/ANSI 55 – 2002 are shown in this addendum as ~~crossouts~~ for deletions and **highlights** for additions.

NSF/ANSI 55 – 2002
Addendum 2.0 – 2002

© 2002 NSF

This page is intentionally blank.

Standards and Criteria²

The following standards and criteria established and adopted by NSF as minimum voluntary consensus standards are used internationally:

- 2 Food equipment
- 3 Commercial warewashing equipment
- 4 Commercial cooking, rethermalization, and powered hot food holding and transport equipment
- 5 Water heaters, hot water supply boilers, and heat recovery equipment
- 6 Dispensing freezers
- 7 Commercial refrigerators and freezers
- 8 Commercial powered food preparation equipment
- 12 Automatic ice making equipment
- 13 Refuse processors and processing systems
- 14 Plastics piping system components and related materials
- 18 Manual food and beverage dispensing equipment
- 20 Commercial bulk milk dispensing equipment
- 21 Thermoplastic refuse containers
- 24 Plumbing system components for manufactured homes and recreational vehicles
- 25 Vending machines for food and beverages
- 29 Detergent and chemical feeders for commercial spray-type dishwashing machines
- 35 High pressure decorative laminates (HPDL) for surfacing food service equipment
- 36 Dinnerware
- 37 Air curtains for entranceways in food and food service establishments
- 40 Residential wastewater treatment systems
- 41 Non-liquid saturated treatment systems
- 42 Drinking water treatment units – Aesthetic effects
- 44 Residential cation exchange water softeners
- 46 Evaluation of components and devices used in wastewater treatment systems
- 49 Class II (laminar flow) biosafety cabinetry
- 50 Circulation system components and related materials for swimming pools, spas/hot tubs
- 51 Food equipment materials
- 52 Supplemental flooring
- 53 Drinking water treatment units – Health effects
- 55 Ultraviolet microbiological water treatment systems
- 58 Reverse osmosis drinking water treatment systems
- 59 Mobile food carts
- 60 Drinking water treatment chemicals – Health effects
- 61 Drinking water system components – Health effects
- 62 Drinking water distillation systems
- 75 Non-potentially hazardous foods
- 116 Non-food compounds used in food processing facilities – Food grade lubricants (draft standard for trial use)
- 170 Glossary of food equipment terminology
- 173 Dietary supplements
- 184 Residential dishwashers
- 14159 Safety of machinery – Hygiene requirements for the design of machinery
- 14159-1 Hygiene requirements for the design of meat and poultry processing equipment
- C-2 Special equipment and/or devices

² The information contained in this Standards and Criteria page is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Standards and Criteria page may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.



THE HOPE OF MANKIND rests in the ability of man to define and seek out the environment which will permit him to live with fellow creatures of the earth, in health, in peace, and in mutual respect.